

Execution of activities

PARMESS

MAM Cleanroom Measurement



In the following, all times are shown in local time with the corresponding UTC offset.

Print date: 09. Apr 2025 (Europe/Berlin (UTC +2:00))

Page 1 of 1

Protocol sheet

Measure. point group: MKLTST_MPG_Activity_Demo
Description: Demo measurement point group for reporting services
Start measuring: 09. Apr 2025

Description:	Demo_Filter	Number:	105
Short text:	Disassemble the filter grille		
Long text:	Dismantle the grid and keep it off the floor.		
Measured on:	09. Apr 2025 08:39:46	With result:	O
Description:	Demo_Filter_Ins	Number:	107
Short text:	Clean and install the filter screen		
Long text:	After dismantling, clean the grid and reinstall it.		
Measured on:	09. Apr 2025 14:45:32	With result:	O
Description:	Demo_Nightmode	Number:	108
Short text:	Set automatic night mode		
Long text:	During block maintenance, reheating of the tunnel to automatic night mode is skipped due to follow-up tasks. Outside of block maintenance, after measurement/calibration, the tunnel temperature must be reset to automatic night mode. Both procedures are to be confirmed with 'ok'.		
Measured on:	09. Apr 2025 15:22:54	With result:	O
Description:	Demo_Tunnel	Number:	106
Short text:	Adjust tunnel bulkhead height		
Long text:	Tunnel bulkhead re-adjusted to original packaging height/value.		
Measured on:	09. Apr 2025 16:50:57	With result:	O

Measuring notebook: VMWIN11MOQLERO

Comment: n.d.

Executed by: Doe, John (jdoe)

Participants: n.d. n.d.